

## TJ255PE

## Diesel Generator Sets (50 Hz / 60 Hz)

Power Output Ratings		50 Hz / 400 V	60 Hz / 440 V
Standby Power (ESP)	kVA	253	275
	kW	203	220
Prime Power (PRP)	kVA	231	249
	kW	185	200

Engine					
Manufacturer		PERKINS			
Origin		U.S.A.			
Model		1306C-E	1306C-E87TAG4		
No of Cylinder / Configuration		6 - INLINE			
Displacement	it	8,7			
Bore / Stroke	mm	116,6 / 135,9			
Compression Ratio		16,9:1			
Aspiration		Turbocharged and Air to-Air Charged Cooled			
Governor Type		ELECTRONIC/ECM			
Cooling System		WATER			
Coolant Capacity	lt	37,2			
Lubrication Oil Capacity	lt	28,3			
Electrical System	VDC	24			
Speed / Frequency		1500 rpm / 50 Hz	1800 rpm / 60 Hz		
Engine Gross Power	kWm	224	242		
	110 %	53	61		
Fuel Consumption It/h	100 %	48,5	54,4		
i dei consumption	75 %	37,5	40,3		
	50 %	26,1	27,9		
Exhaust Outlet Temperature °C		526	477		
Exhaust Gas Flow	m³/min	40,3	51,3		
Combustion Air Flow	m³/min	14,9	20,2		
Cooling Air Flow	m³/min	375	480		

Alternator				
Manufacturer		MARELLI		
Origin		ITALY		
Model		MJB250LB4		
No of Phase		3		
Power Factor		0,8		
No of Bearing		SINGLE		
No of Poles		4		
No of Leads		12		
Voltage Regulation ( Steady State)		± %0,5		
Insulation Class		Н		
Degree of Protection		IP 23		
Excitation System		AVR (Automatic Voltage Regulator), Brushless		
Connection Type		STAR		
Total Harmonic Content (No Load)		< %2		
Frequency	Hz	50	60	
Voltage Output	VAC	230 / 400	254 / 440	
Rated Power (Standby)	kVA	275	305	
Efficiency	%	93,4	93,7	

	WxLxH(mm)	Weight (kg)	Fuel Tank (It)	Noise (dBA)
Canopied	1237 x 3919 x 1950	2635	385	TBA
Open Skid	950 x 3000 x 1530	2015	385	TBA






## Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

## Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards.
- Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.
- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

TBA: To Be Ask TBD: To Be Determined NA: Not Avaliable N/A: Not Applicable www.teksangenerator.com

TTD255PE0309-EN

