

TJ720PE

Diesel Generator Sets (50 Hz / 60 Hz)

Power Output Ratings		50 Hz / 400 V	60 Hz / 440 V
Standby Power (ESP)	kVA	721	709
	kW	577	568
Prime Power (PRP)	kVA	669	644
	kW	535	515

Engine				
Manufacturer		PERKINS		
Origin		U.S.A.		
Model		2806A-E18TAG2		
No of Cylinder / Configuration		6 - INLINE		
Displacement	lt	18,13		
Bore / Stroke	mm	145 / 183		
Compression Ratio		14,5:1		
Aspiration		Turbocharged and Air to Air Charged Cooled		
Governor Type		ELECTRONIC/ECM		
Cooling System		WATER		
Coolant Capacity	lt	61		
Lubrication Oil Capacity	lt	62		
Electrical System	VDC	24		
Speed / Frequency		1500 rpm / 50 Hz	1800 rpm / 60 Hz	
Engine Gross Power	kWm	628	623	
	110 %	143	141	
Fuel Consumption It/h	100 %	132	127	
	75 %	97	95	
	50 %	66	66	
Exhaust Outlet Temperature	°C	553	489	
Exhaust Gas Flow	m³/min	114	118	
Combustion Air Flow	m³/min	40	45	
Cooling Air Flow	m³/min	702	852	

Alternator				
Manufacturer		MARELLI		
Origin		ITALY		
Model		MJB355MA4		
No of Phase		3		
Power Factor		0,8		
No of Bearing		SINGLE		
No of Poles		4		
No of Leads		12		
Voltage Regulation (Steady State)		± %0,5		
Insulation Class		Н		
Degree of Protection		IP 23		
Excitation System		AVR (Automatic Voltage Regulator), Brushless		
Connection Type		STAR		
Total Harmonic Content (No Load)		< %2		
Frequency	Hz	50	60	
Voltage Output	VAC	230 / 400	254 / 440	
Rated Power (Standby)	kVA	750	855	
Efficiency	%	94,7	94,9	

	WxLxH(mm)	Weight (kg)	Fuel Tank (It)	Noise (dBA)
Canopied	1687 x 5019 x 2600	5505	1000	TBA
Open Skid	1550 x 3700 x 2250	4400	1000	TBA






Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards.
- Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.
- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

TBA: To Be Ask TBD: To Be Determined NA: Not Avaliable N/A: Not Applicable www.teksangenerator.com

TTD720PE0309-EN

